

2018 ASPHALT SPOT PAVING,
Project #5-2018
Request For Clarification During Bid Process

	Date	Contractor	Submitter	Question	Response
	<p>Item 00130 - Supplemental Specifications, contains the specifications for "Thin-Lay" Asphalt Concrete Pavements. Bidders should review this section carefully. There was some last minute "tweaking" to the Exceptions in Item 00130, Section 5. Exceptions to the ODOT Spec are: • Blow Count for Type MED, Type LT and Type ULT are decreased from 50 to 35. • RAP (Maximum %) shall be limited to 20% for all Types.</p>				
1	4/17/18	Gerken Paving	John	Can we look at your field work used to calculate quantities for this project.	Yes, We will attach them to this document, however we won't add them to Contract Documents.