

2020 Norlick Drive - Norlick Place Subdivision
 Project #4-2020
 Request For Clarification During Bid Process

Date		Contractor	Submitter	Question	Response
1	3/10/20	Gerken Paving	John	I have a question regarding the material type to be used for the intermediate course. Plan sheet # 2 – Typical Section shows Ty 1, Plan sheet # 9 – Quantity Summary shows Ty 2, Supplemental Spec 00130 page # 5 – calls out Ty 1, Bid Form Item # 9 calls out Ty 2. By contract hierarchy, the Bid Form prevails with the Ty 2 called out. Is Ty 2 what you want used for the intermediate?	Yes, Type 2, Intermediate is the plan. We will officially correct the errors in a future addendum
2	3/23/20	Bryan Excavating	Jerry	Can you clarify the LSM for the Sanitary Sewer type B conduit?	Yes, we will detail in Addendum 1 with dimension, depth, and an LSM spec.
3	3/23/20	Bryan Excavating	Jerry	Is as the concrete collar shown for storm MH on the drawings applicable for the sanitary manhole.	Yes, we will detail in Addendum 1, both will require concrete collars.