

2022 ASPHALT PAVING PROGRAM  
 Project #3-2022  
 Request For Clarification During Bid Process

	Date	Contractor	Submitter	Question	Response
	3/15/22	Gerken Paving	John Helberg	On RD I, in the areas of the 2" Milling, will the intermediate course still be 3/4" the same as in the 1.5" milling Areas, or will the intermediate thickness need to be increased to 1.25"?	The Intermediate thickness will be the same regardless of the milling depth.
	3/15/22	Gerken Paving	John Helberg	I am not finding a note on the milling dump site. Do you want the millings off of Road I or do they go to the contractor?	The Millings go to the contractor. The Intermediate course is 1/2" We have a 3/4" Typo on sheet 2
	3/15/22	Gerken Paving	John Helberg	The typical section, sheet 2 shows 3/4" intermediate course thickness, but quantity computes to 1/2". Which is correct?	The Intermediate course is 1/2" thick, we have a 3/4" Typo on sheet 2.