

WIL-CR 202-2.18 BRIDGE REHABILITATION (03200 CR 20)
Request For Clarification Log (RFC) - Bid Date 3/19/18
Project #3-2018

Date		Contractor	Submitter	Question	Response
1	2/15/18	FYI to All Potential Bidders	Project Engineer	North Western Electric is currently in the process of building a loop around the project on an adjacent County Road, which will allow them to de-energize the power lines over the bridge deck during all or most of the construction. The work is estimated to be completed by April 30, 2018.	
2	3/16/18	R G Zachrich	Steve Lange	Is the full application of 514 applicable	Yes, and the Owner also plans to hire a prequalified independent Coatings Inspector.
3	3/16/18	Miller Brothers	Issac Burns	Sheet 14 denotes that the existing approach slab removal is to be paid for under Item 202 – Approach Slab Removed. However there is no bid item for this. Will a bid item be created for this work?	The time period has passed for an addendum for this project. The cost associated for this work will need to be negotiated and authorized by a change order, approved by both the Owner and ODOT.

