

Office of The Williams County Engineer

Todd J. Roth, P.E., P.S.

troth@wmscoengineer.com

ADDENDUM NO. 1

Date of Addendum: December 22, 2020

BRUCE DRIVE STORM SEWER
Project #1-2021

Bid Date: January 7, 2021

TO ALL BIDDERS:

Bidders should also be aware of the following changes to the bidding documents:

Quantity Change Bid Item 1 12" Type B.	Est Quantity	164 FT
Quantity Change Bid Item 2 12" Type C.	Est Quantity	836 FT
Total Estimated Cost		\$115,751.21

All 6" and 8" Service Lines are to be capped. Caps shall be compatible with the service lines. A stake from the flow line to six inches or less below finished grade shall be placed at the end of the service line.

Plan holders will be advised of this Addendum and revised documents will be posted on the Williams County Engineer's Web Page at:
<http://www.wmscoengineer.com/bidprojects.asp>

Respectfully,



Todd J. Roth, P.E., P.S.
Williams County Engineer

ENGINEER