

BRIDGE REPLACEMENT 02220 COUNTY ROAD Q.50 - DEW01  
 Project #3-2020  
 Request For Clarification During Bid Process

BRIDGE REPLACEMENT 02220 COUNTY ROAD Q.50 - DEW01 Project #3-2020 Request For Clarification During Bid Process					
Date	Contractor	Submitter	Question	Response	
1	2/7/20	Engineer	There are repeated numbers in the Bid Item column on the Bid Form.	Corrections will be made in a future Addendum	
2	2/10/20	R G Zachrich	Steve	Do you have a soil report for this project.	Yes, we will immediately post it on the web page and formally address its existence in a future addendum.
3	2/12/20	Gerken Paving	John	Bid sheets call out Ty 1 for the base asphalt, intermediate, and surface. Typical section shows Ty 2 base, TY 2 interm, and Ty 1 surface. Based on the way it is set up (proposal prevails), the Ty 1 base, Ty 1 interm, and Ty 1 surface would prevail. Is this what you want?	Type 1 across the board will be satisfactory. We will address this matter in a future addendum.