

BRIDGE AND CULVERT REPLACEMENT PROGRAM - DEX02
 Project #3-2021
 Request For Clarification During Bid Process

BRIDGE AND CULVERT REPLACEMENT PROGRAM - DEX02 Project #3-2021 Request For Clarification During Bid Process					
Date		Contractor	Submitter	Question	Response
1	2/23/21	Bryan Excavating	Jerry	Are drawing scaled correctly?	On both P & P sheets (Sheets 4 & 11) Scale Legends show 20 but are actually 30. Drawings will be revised in a future addendum.
2	2/24/21	Engineer		ODOT Prequalification	ODOT Prequalification will not be required. Item 00100, S 3.3 will be revised. Matter will be addressed in a future addendum.
3	3/10/210	Bryan Excavating	Tom	Two trees will need to be removed on CR 10.50. Is a separate bid item missing?	The cost of the tree removal should be included in Bid Item 1, 202, Clearing and Grubbing. Matter will be addressed in a future addendum.