

2020 COUNTY ROAD J AND SPOT PAVING
Project #5-2020
Request For Clarification During Bid Process

Date		Contractor	Submitter	Question	Response
1	4/15/20	Gerken Paving	John	In the Spot Paving portion, all of the SS823 Surface Course items have an "*" included in the description, I cannot find a "*" note. What does this refer to?	Nothing, Asterisk will be removed from Bid Forms. This and changes below will be addressed in a future Addendum
		Gerken Paving	John	The Spot Paving portion, including the Center Twp. portion, does not include Tack Coat items, where is the Tack Coat paid?	Items 13a thru 17a Include Tack cost in the Asphalt Cost. Note will be added to the bid form.
		Gerken Paving	John	The Rd J section includes a Ref #5 407 Tack Coat, is K-Teck NT Trackless Tack an acceptable option in this section as well in the Spot Paving section wherever the tack is paid for in that section?	The K-Tech NT Trackless is an approved option for Bid Item 5 and any other Tack Work.
		Gerken Paving	John	Ref #17a – Special – Thinlay includes "As Per Plan" in the description; what does the "As Per Plan" indicate?	As Per Plan will be removed from the bid form.
		Gerken Paving	John	On Co Rd A, Ref #13a – there are a significant number of potholes on this road; will these be filled by others?	Yes, Williams County will fill the holes.
		Gerken Paving	John	On Co Rd A, Ref #13a – 1.75" of SS823 is specified; due to the existing grade differentials, should this be split into a ½" to ¾" scratch and 1.0" to 1.25" surface with a 1.75" avg?	Bid Form will be revised to include .50" scratch and 1.25 surface courses.
		Gerken Paving	John	Does the Estimate include the 10% for contingencies?	Yes, Estimate will be revised in future Addendum
2	4/23/20	Gerken Paving	John	On Center Twp, Sunrise Sub, Ref #17a, there is significant amounts of crack seal; is this crack seal type used susceptible to expansion with the heat of the asphalt placed on it? If so or unknown, since this road is only a 1" overlay, should a thin milling item be included to remove the crack seal material?	The Township advises that all of the crack seal on Sunrise is the same material that has been used on the two previous "Thinlay Projects", with good results. Township believes the results will be similar on this project.
		Gerken Paving	John	On Center Twp, Sunrise Sub, Ref #17a, there are some hard surface mailbox approaches other than asphalt along with some significant pavement stress next to these locations; what will happen at these hard surface locations and how will the pavement repairs be handled?	The Township plan is to pave straight though and not "kick out" for drives or mailboxes. The Township will follow the paving with any necessary berm back up. Additional quantity will be added to Item 17a for scratch work on Sunrise Drive prior paving as directed by the Township.