

WIL-COOPER FARMS  
 CONCRETE DRIVE APRON  
 Proposal #3-2019  
 Request For Clarification During Bid Process

	Date	Contractor	Submitter	Question	Response
1	4/4/19	Schimmoeller Construction	Craig Schroeder	There is a 24"x36" drawing in the bid documents dated 3/28/19. There is an 8-1/2" x 11" sheet also that was dated 2/16/18 and has permit stamped with that date also. These two drawings have discrepancies between them. Which drawing do we use to bid off of?	Use the 24x36 set with the notation REQUEST FOR QUOTATION SET dated 3/28/19. The drawings in the project manual are related to the ODOT Permit which basically establishes an ODOT minimum standard. The request for quotation set has increased radii to accommodate truck traffic. The Original permit in the proposal manual had expired and a permit renewal has been inserted into the proposal manual. Drawings in the revised permit also reflect the minimum standard.
2					
3					