

LOVE'S TRAVEL STOP SANITARY SEWER
Request For Clarification Log (RFC) - Bid Date 7/19/18
Project #6-2018

Date	Contractor	Submitter	Question	Response
1	6/26/18			Please Note: In a future Addendum Bid Item 6 will be formally changed from HDPE to 4" PVC FORCE MAIN SDR 26 (OPEN CUT). Early versions posted on line called out HDPE. Sheet S2.0 of the Drawings will also be revised to reflect this change.
2	7/6/18			Please Note: Addendum 1 Issued 7/6/18. Emailed to Plan Holders and Posted on Engineer's Web Page
3	7/16/18			Please Note: Addendum 2 & 3 Issued 7/16/18. Emailed to Plan Holders and Posted on Engineer's Web Page
4	7/17/18			Please Note: Further Clarification on Addendum 2 & 3. It is the intent of the Customer and Engineer that the Base Bid for Item 10 include Item H Chopper Pump as noted on Sheet 5.1, DWG Q4167-021418. Other pump options should be included with an Or Equal pump station in Additive Alternate 1.

